

No. FS/NOC/BLDG (O)/2024/1/1953
GOVERNMENT OF MIZORAM
FIRE & EMERGENCY SERVICES DEPARTMENT
MIZORAM: AIZAWL

Dated: Aizawl, the 8th November, 2024

NO OBJECTION CERTIFICATE (PROVISIONAL)

This is to certify that the undersigned has no objection on the following Eklavya Residential Model School buildings located at Bilkhawthlir subject to installation of the following Fire Fighting measures arrangement based on the provision of *Part IV of NBC, 2016* as mentioned below:

Sl. No	Name of Buildings	Fire fighting equipment to be provided
1.	Principal Quarters	1.ABC 4kg-1 No. 2. CO2 2kg 1 No. 3. Fire Alarm and Smoke detector
2.	Teaching Staff Quarters	1.ABC 4kg-3 Nos. 2.CO2 2kg-3Nos. 3.Fire Alarm and Smoke detector
3.	Teaching Staff Quarters	1.ABC 4kg-3 Nos. 2.CO2 2kg-3 Nos. 3.Fire Alarm and Smoke detector
4.	Non Teaching Staff Quarters	1.ABC 4kg-3 Nos. 2.CO2 2kg-3Nos. 3.Fire Alarm and Smoke detector
5.	Class Room(3 Stories)	1.ABC 4kg-6 Nos. 2.CO2 2kg-7 Nos. 3.Fire Alarm and Smoke detector
6.	Boys Hostel	1.ABC 4kg-6 Nos. 2.CO2 2kg-6 Nos. 3.Fire Alarm and Smoke detector
7.	Girls Hostel(3 Stories)	1.ABC 4kg-6 Nos. 2.CO2 2kg-6Nos. 3.Fire Alarm and Smoke detector
8.	Guest Room	1.ABC 4kg-1 No. 2.CO2 2kg-1 No. 3.Fire Alarm and Smoke detector
9.	Kitchen cum Dining Hall	1.ABC 4kg-3 Nos. 2.CO2 2kg-3 Nos. 3.AB Foam type 1 No. 3.Fire Alarm and Smoke detector

This Provisional NOC is valid for 2 (two) years which may be renewed for another 2 (two) years on receipt of proper application indicating the reason for its renewal. Final NOC will be issued after satisfactory inspection report about the installation of the above Firefighting arrangements is received.




(ZOSANGLIANA)
Director

Fire & Emergency Services
Mizoram : Aizawl